



Jim Doyle, Governor Mary P. Burke, Secretary

August 25, 2006

INTERNATIONAL PRODUCTION SPECIALISTS JAY BANDHOLZ 35006 WASHINGTON AVE PO BOX 125 HONEY CREEK WI 53138

Re: Description: SEWAGE TANKS, STEEL

Manufacturer: INTERNATIONAL PRODUCTION SPECIALISTS

Product Name: HOLDING OR PUMP

Model Number(s): 3000/H3MS

(59.5" L.L., 72" MAX. DEPTH OR BURY)

Product File No: 20060383

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
 department's stamp of approval. The plans and specifications must be open to inspection by an authorized
 representative of the department.
- The products produced by this manufacturer are approved to use the following:
 - Bolt on anodes.
 - One inch opening for electrical connections.
 - Internal support rings spaced evenly along tank.
 - Optional 6", 8", or 10" threaded plug in access cover.
 - Flip top access cover or bolt down cover with or without gasket.
 - 3", 4" or 6" diameter suction pump extension with coupling located at either end or in top of tank.
 - 2" opening for vent connection.
 - 4", 6" or 8" inlet and/or outlet.

This approval supersedes the approval under product file number 20050889.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST Engineering Consultant--Plumbing Product Reviewer Commerce; Safety & Buildings Div. PO Box 2658; 201 W Washington Ave.

Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 06038303.DOC